



CERTIFICATE OF ANALYSIS

Customer : RAMM Environmental Services, INC
77 Nottingham Road
Fair Lawn, NJ 07410

Project ID : Titusville Academy, 86 River Dr Titusville, NJ
PAS Project ID : P25-04950

Matrix : Drinking Water
Report Date : 6/20/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-04950-01	Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:00	6/9/25 17:40
P25-04950-02	Kitchen Sink	Lead	1.93 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:02	6/9/25 17:44
P25-04950-03	Kitchen Cooler	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:04	6/9/25 18:01
P25-04950-04	Room #1 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:07	6/9/25 18:06
P25-04950-05	Room #2 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:09	6/9/25 18:10
P25-04950-06	Room #3 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:11	6/9/25 18:15
P25-04950-07	Room #5 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:14	6/9/25 18:28
P25-04950-08	Room #6 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:16	6/9/25 18:33
P25-04950-09	Nurse Room (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:18	6/9/25 18:37
P25-04950-10	Room #8 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:22	6/9/25 18:41
P25-04950-11	Room #7 (Cooler)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:24	6/9/25 18:46
P25-04950-12	Hallway by Main Office Wtr Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/5/25 10:27	6/9/25 18:51

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer